


Building Safety Certificate

Certified that the building of "D.A.V. Centenary Public School" has been constructed on Khasra No. 780/396 & 781/683 at Reckong Peo, Tehsil Kalpa Distt. Kinnaur H.P. as per approved plan and design as per IS code. The School is already affiliated with the CBSC New Delhi and is seeking renewal / up gradation. The inspection of the building has already been conducted.

Authorized signatory Chairman/Principal
"D.A.V. Centenary Public School"
at Reckong Peo, Tehsil Kalpa Distt. Kinnaur H.P.

Certified that the building of "D.A.V. Centenary Public School" at Reckong Peo, Tehsil Kalpa Distt. Kinnaur H.P. is functioning in accommodation of said building/school at Reckong Peo has been got inspected through Assistant Engineer, Peo Sub-Division, HP. PWD., Peo along with Junior Engineer, Peo section on 09.07.2019 and reported that the a building consist of three stories R.C.C. framed structure and brick masonry walls. Public Works Department has never supervised the construction of this building at any stage. No detailed structural analysis and drawings in seismic and non-seismic conditions are available/were provided to check the safety of building. Foundation depth, quality and quantity of material used and cement concrete ratio used is not known to HPPWD department. However presently by visual inspected the said building seems to be safe for running the School for the academie session 2019-20 under normal conditions except in case of natural calamities i.e. earth quake, cloud burst, flood, unequal settlement etc.


Assistant Engineer
Sub-Division, R/Peo
HPPWD, R/Peo


Executive Engineer.
Kalpa Division,
H.P. PWD; Kalpa

No. PW/KNR/Blds./2019/ 3107-08
Copy forwarded to the followings:-

Dated:- 15th 7/2019

1. The Chairman/Principal "D.A.V. Centenary Public School" at Reckong Peo , Tehsil Kalpa Distt. Kinnaur H.P.
2. The Assistant Engineer, Peo Sub-Division HPPWD. R/ Peo, Distt. Kinnaur H.P.


Executive Engineer.
Kalpa Division,
H.P. PWD; Kalpa